

Commonwealth of Virginia  
Division of Consolidated Laboratory Services

600 North 5th St.  
Richmond, Virginia 23219  
804-648-4480



**REPORT OF ANALYSIS**

Report Date: 04/24/2024  
DCLS LIMS #: E240304946

**Mail To**

HIGH KNOB UTILITIES  
17 WINDY WAY  
FRONT ROYAL, VA 22630

PWSID 2187522  
REGION 2

**Sample Information**

DATE RECEIVED	04/17/2024 09:28	LOCATION	020 - ALPINE
SAMPLING DATE	04/16/2024 08:20	RESIDUAL CHLORINI	0.43
COLLECTED BY	GARRISON MYER	CHLORINE TYPE	FREE
SAMPLE MATRIX	DRINKING WATER	FACILITY	DS950
ORDERED TEST	206-062 MW COLIPA	FACILITY DESC	HIGH KNOB
PROJECT NAME	DW2024-Q2	TYPE	RT
		CATEGORY	TC
		ORDER NUMBER	98169

**Test Results**

APPROVED BY: JFONVILLE, Scientist Senior      DATE APPROVED: 04/24/2024

<u>METHOD</u>	<u>PARAMETER</u>	<u>RESULT</u>	<u>ANALYSIS DATE</u>
<u>SM 9223 B</u>	Total Coliforms by Colisure	Absent	04/18/2024 15:00
	E. Coli by Colisure	Absent	04/18/2024 15:00

**Explanation of Terms and Disclaimers**

PMCL is defined as the "Primary Maximum Contaminant Level." SMCL is defined as the "Secondary Maximum Contaminant Level". If blank, level not defined by EPA. Results denoted with an asterisk (\*) indicate that the PMCL is exceeded. Test Results meet requirements of NELAP. Non-NELAP accredited analyses noted by ^^. The results included on this report relate only to this specific sample and not to other samples tested from this sampling location.

**CONFIDENTIALITY NOTICE:** This report contains PRIVILEGED and CONFIDENTIAL INFORMATION. This report should not be reproduced, except in full, without the written approval of DCLS. If you have received this report in error, please notify DCLS immediately at (804) 648-4480 Ext. 171.

Commonwealth of Virginia  
 Division of Consolidated Laboratory Services

600 North 5th St.  
 Richmond, Virginia 23219  
 804-648-4480



**REPORT OF ANALYSIS**

Report Date: 04/24/2024  
 DCLS LIMS #: E240304945

**Mail To**

HIGH KNOB UTILITIES  
 17 WINDY WAY  
 FRONT ROYAL, VA 22630

PWSID 2187522  
 REGION 2

**Sample Information**

DATE RECEIVED	04/17/2024 09:28	LOCATION	050 - DOUGLAS
SAMPLING DATE	04/16/2024 09:40	RESIDUAL CHLORINI	0.37
COLLECTED BY	GARRISON W. MYER	CHLORINE TYPE	FREE
SAMPLE MATRIX	DRINKING WATER	FACILITY	DS950
ORDERED TEST	206-062 MW COLIPA	FACILITY DESC	HIGH KNOB
PROJECT NAME	DW2024-Q2	TYPE	RT
		CATEGORY	TC
		ORDER NUMBER	98169

**Test Results**

APPROVED BY: JFONVILLE, Scientist Senior

DATE APPROVED: 04/24/2024

<u>METHOD</u>	<u>PARAMETER</u>	<u>RESULT</u>	<u>ANALYSIS DATE</u>
<i>SM 9223 B</i>	Total Coliforms by Colisure	Absent	04/18/2024 15:00
	E. Coli by Colisure	Absent	04/18/2024 15:00

**Explanation of Terms and Disclaimers**

PMCL is defined as the "Primary Maximum Contaminant Level." SMCL is defined as the "Secondary Maximum Contaminant Level". If blank, level not defined by EPA. Results denoted with an asterisk (\*) indicate that the PMCL is exceeded. Test Results meet requirements of NELAP. Non-NELAP accredited analyses noted by ^^ . The results included on this report relate only to this specific sample and not to other samples tested from this sampling location.

**CONFIDENTIALITY NOTICE:** This report contains PRIVILEGED and CONFIDENTIAL INFORMATION. This report should not be reproduced, except in full, without the written approval of DCLS. If you have received this report in error, please notify DCLS immediately at (804) 648-4480 Ext. 171.

Commonwealth of Virginia  
Division of Consolidated Laboratory Services

600 North 5th St.  
Richmond, Virginia 23219  
804-648-4480



**REPORT OF ANALYSIS**

Report Date: 04/18/2024  
DCLS LIMS #: E240304951

**Mail To**

HIGH KNOB UTILITIES  
17 WINDY WAY  
FRONT ROYAL, VA 22630

PWSID 2187522  
REGION 2

**Sample Information**

DATE RECEIVED	04/17/2024 09:56	LOCATION	SPRING NO.5+6
SAMPLING DATE	04/16/2024 08:30	FACILITY	SP005
COLLECTED BY	GARRISON W. MYER	FACILITY DESC	SPRING NO. 5 & 6
SAMPLE MATRIX	DRINKING WATER	TYPE	RT
ORDERED TEST	206-086 MPN QT	CATEGORY	GE
PROJECT NAME	DW2024-Q2	ORDER NUMBER	98169

**Test Results**

APPROVED BY: JFONVILLE, Scientist Senior      DATE APPROVED: 04/18/2024

<u>METHOD</u>	<u>PARAMETER</u>	<u>RESULT</u>	<u>ANALYSIS DATE</u>
<u>SM 9223 B</u>	TOTAL COLIFORM BY QUANTI-	9.7 MPN/100ml	04/18/2024 14:25
	E. COLI BY QUANTI-TRAY, MPN	<1MPN/100ml	04/18/2024 14:25

**Explanation of Terms and Disclaimers**

PMCL is defined as the "Primary Maximum Contaminant Level." SMCL is defined as the "Secondary Maximum Contaminant Level". If blank, level not defined by EPA. Results denoted with an asterisk (\*) indicate that the PMCL is exceeded. Test Results meet requirements of NELAP. Non-NELAP accredited analyses noted by ^^.

**CONFIDENTIALITY NOTICE:** This report contains PRIVILEGED and CONFIDENTIAL INFORMATION. This report should not be reproduced, except in full, without the written approval of DCLS. If you have received this report in error, please notify DCLS immediately at (804) 648-4480 Ext. 171.